



**ADDENDUM NO. 1
ADMINISTRATION BUILDING PAYMENT KIOSK
RFQ Due Date: June 12, 2019
Quotation Number 191004**

TO ALL PLANHOLDERS:

The Request for Quotation and all bid documents for the above-named project are hereby amended in the following particulars; all other items and conditions remaining unchanged:

- 1) Building soffits to be open and painted (color to be selected by Owner).
- 2) Door and Jamb to be painted (color to match soffits).
- 3) Door hardware to be Schlage Lock Co. Model D80TD or approved equal. (Commercial knob with keyed entry to come with temporary construction core, the Owner to supply and install locking core keyed to their standard).
- 4) Interior of structure to be open studs.
- 5) It is intended that the proposed light and kiosk be powered off of the same circuit as the gate actuator at the point of connection. Contractor to provide conductors from point of connection shown on plans to the building and light pole. Contractor to perform final connection to the proposed light. The Owner to provide final connection to proposed Kiosk. No panel was planned for this installation. The Owner to provide communications wiring and final hook-up.
- 6) The light pole is to be provided with an integrated photo-electric control to allow for "dusk-to-dawn" control.
- 7) Contractor will be responsible for layout/surveyor. CAD drawings of the site are available for use by the surveyor.

This addendum consists of one (1) page. This addendum must be acknowledged and included with any bid submitted.

PUBLIC UTILITY DISTRICT
NO. 1 OF CLALLAM COUNTY

By: 
John Purvis, Assistant General Manager

Date: 6/6/19

Acknowledged by:

(Bidder)

By: _____

Date: _____